







NOTE

1. IMPROVED SIDESLOPES SHALL BE 4:1 OR FLATTER AS REQUIRED BY THE CONSULTANT. 
2. UNDERCUT SHALL BE BENCHED, OR IF STRAIGHT CUT IS USED FOR THE FULL DEPTH OF THE EMBANKMENT, THE CUT SHALL NOT BE STEEPER THAN 0.5 HORIZONTAL TO 1.0 VERTICAL AS REQUIRED BY THE CONSULTANT. 
3. THIS DRAWING SUPPLEMENTS SPECIFICATION 2.3 GRADING.

| | | | |
|---|------------------------------------|-----|-------|
|  | REVISED UNDERCUT EXCAVATION | PI | 12/00 |
|  | REVISED "ENGINEER" TO "CONSULTANT" | TDN | 07/98 |
|  | ADDED SURFACING DETAILS | TDN | 04/98 |
| No. | REVISIONS | BY | DATE |

| | |
|--|---|
| <p>Approved:</p> <p>ORIGINAL SIGNED BY ALLAN KWAN</p> <p>-----</p> <p>Executive Director, Technical Standards Branch</p> |  |
| <p>Date: July, 1995</p> | |

**TYPICAL CROSS SECTION
FOR
GRADE WIDENING**

| | | | |
|----------------------|---------------------|------------------|------------------------|
| Prepared By: R.M. | Checked By: P.I. | Scale: N.T.S. | Dwg No.: CB6-2.3M56 |
|----------------------|---------------------|------------------|------------------------|