

NOTE: LIFT HOLES SHALL HAVE 80mm INSIDE DIAMETRE AND AN IIOmm OUTSIDE DIAMETRE.

## **ELEVATION VIEW**

## NOTES:

- I. CONCRETE SHALL BE SULPHATE RESISTANT CONCRETE 40 MPg AT 28 DAYS.
- 2. REINFORCEMENT SHALL BE EPOXY COATED REINFORCING BARS.
- 3. REINFORCING STEEL SHALL BE GRADE 400 UNLESS NOTED OTHERWISE.
- 4. EXPOSED SURFACES SHALL HAVE 20mm CHAMFER OR FILLET OR AS OTHERWISE SPECIFIED.
- 5. DIAMETERS OF BENDS AND DETAILS OF HOOKS, UNLESS NOTED OTHERWISE SHALL CONFORM TO THE RECOMMENDED SIZES DETAILED IN THE REINFORCING STEEL INSTITUTE OF CANADA "MANUAL OF STANDARD PRACTICE".
- 6. FOR CONNECTION DETAILS AND 3 DIMENSIONAL VIEW OF BARRIERS SEE DRAWING CB6-4,2M5, M6 AND M7.
- 7. HOOKS AND EYES SHALL BE 150 GALVANIZED STEEL.
- 8. HOOKS AND EYES SHALL BE SECURED IN PLACE DURING CASTING.
- 9. DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED.
- O. HALF F-BARRIERS ARE ONLY TO BE USED WHERE LATERAL SUPPORT IS PROVIDED BEHIND THE BARRIER. THIS TYPE OF BARRIER IS IDEALLY SUITED FOR PLACEMENT AGAINST A WALL FACE OR OTHER VERTICAL STRUCTURE. WHERE LATERAL SUPPORT IS NOT AVAILABLE THE FULL F-BARRIER SHOULD BE USED.

