



1. ALL CONCRETE SHALL BE 40 MPa AT 28 DAYS.
2. ALL REINFORCEMENT SHALL BE EPOXY COATED REINFORCING BARS.
3. ALL EXPOSED CONCRETE SHALL HAVE A SMOOTH SURFACE.
4. EXPOSED SURFACES SHALL HAVE 20mm CHAMFER OR FILLET OR AS OTHERWISE SPECIFIED.
5. ALL SURFACES SHALL BE FORMED WITH OILED PLYWOOD OR STEEL FORMED FINISH
6. ALL VOIDS ARE TO BE CAPPED AND WATERPROOFED
7. EXPOSED SURFACES SHALL HAVE AN APPROVED SEALING SOLUTION APPLIED

ALL DIMENSIONS ARE IN MILLEMETRES
UNLESS OTHERWISE NOTED

FOR RETROFIT ONLY

A	CURB REMOVED FROM TITLE	BK.	04-17-07
		REVISIONS	BY DATE
No.			
		Effective Date:	1997
		REINFORCED CONCRETE MEDIAN BARRIER Δ NJ SHAPE	
Prepared By:	N.N.	Checked By:	B.K.
Scale:	N.T.S.	Dwg No.:	CB6-4.3M1A