40 x 90 BEVELLED SHEAR KEY	NO SHEAR KEY REQUIRED UNLESS SHOWN ON DRAWINGS EY		
REBA	1 40 v	TAPERED KEY REBAR 40 40 40 TAPERED KEY REBAR CONTINUOUS I mm GALV STEEL (OR 100 mm PVC WATERSTOP WHEN APPROVED BY THE ENGINEER)	
THIN WALL DETAIL	PIER SHAFT DETAIL	SLAB DETAIL	

GENERAL NOTES

- . DIMENSIONS ARE GIVEN IN mm. DETAILS ARE NOT TO SCALE.
- GALVANIZED STEEL OR PVC WATERSTOP SHALL BE SUPPLIED BY THE CONTRACTOR AND WILL REQUIRED DEPARTMENTAL APPROVAL.
- · JOINTS SHALL BE CLEANED PRIOR TO PLACING CONCRETE AS REQUIRED BY THE CURRENT CONSTRUCTION SPECIFICATIONS.

DRAFTING STANDARDS PAGE: 6.3

A					Alberta TRANSPORTATION AND UTILITIES BRIDGE ENGINEERING BRANCH
					STANDARD
Λ	87-03-04	4 REDRAWN FROM S-1412		DHQ	
NO	DATE	REVISIONS		BY	CONSTRUCTION JOINTS
	IGNED DRAV		APPROVED EXECUTIVE DIRECTOR	m	Signature Date PAGE 1 S-1412-87