



**PIPE SLEEVE DETAIL**

**GENERAL NOTES**

- DIMENSIONS ARE GIVEN IN mm. DETAILS ARE NOT TO SCALE.
- PIPE SLEEVES WILL BE SUPPLIED BY THE DEPARTMENT.

**REQUIREMENTS AND PROCEDURE FOR SPLICING TIMBER PILES**

1. THE PILE ENDS BEING SPLICED SHALL HAVE DIAMETERS OF 280 mm OR GREATER.
2. DRIVING OF THE BOTTOM PILE SHALL BE STOPPED APPROXIMATELY 600 mm ABOVE GROUND OR WATER LINE.
3. DAMAGED PILE ENDS SHALL BE TOTALLY REMOVED BY MAKING SQUARE CUT-OFFS.
4. THE PIPE SLEEVE SHALL BE CENTRED, AND TAPPED PARALLEL, THE FULL 600 mm DISTANCE ONTO THE PILE.
5. THE UPPER PILE END SHALL BE SQUARED, CENTRED ON THE TOP OF THE PIPE SLEEVE, AND TAPPED DOWN INTO THE SLEEVE, KEEPING THE UPPER PILE ALIGNED WITH THE LOWER PILE.
6. THE TOP OF THE PILE SPLICE SHALL END UP NOT LESS THAN 250 mm BELOW GROUND LINE.

**SUPERSEDED** BY S-1413-87 REV 2 (94-11-30) ON SHEET 4  
 SUPERSEDED BY S-1413-87 Rev 2 on Sheet 4

DRAFTING STANDARDS PAGE: 3.8

				<b>Alberta</b> TRANSPORTATION AND UTILITIES BRIDGE ENGINEERING BRANCH			
				<b>STANDARD          TIMBER PILE SPLICE</b>			
DESIGNED	DRAWN	DATE	APPROVED	SIGNATURE	DATE	PAGE	DRAWING
DHQ	MIK	87-03-05	EXECUTIVE DIRECTOR	<i>mmbryd</i>	May 8/87	3.9	S-1413-87