

Bridge Culvert Inspection			
Bridge File Number	13330 -1 Bridge Culvert	Form Type	CUL1
Year Built	1995	Lot No.	4
Bridge or Town Name	WHITLA	Inspector Name	Tom Carey
Located Over	THIRTY MILE COULEE, 2.7.1.7, WATERCRS-ST	Inspector Class	BR CLS A
Located On	885:04 C1 38.136	Assistant Name	
Water Body Cl./Year		Assistant Class	
Navigabil. Cl./Year		Inspection Date	13-Mar-2012
Legal Land Location	SW SEC 12 TWP 10 RGE 9 W4M	Data Entry By	Anne Roberts
Longitude, Latitude	-111:06:39, 49:48:10	Data Entry Date	10-Apr-2012
Road Authority	Alberta Transportation (AIT)	Reviewer Name	Garry Roberts
Contract Main. Area	CMA24	Review Date	25-Mar-2012
Clear Roadway/Skew	10 / -4 deg. (LHF)	Dept. Reviewer Name	Tim Davies
AADT/Year	230 / 2011 (A)	Dept. Review Date	17-Apr-2012
Road Classification	RAU-209-110	Follow-Up By	
Detour Length (km)	6		

Bridge Culvert Information

Number of Culverts	1							
Pipe #	Barrel	Span	Rise (or Dia.)	Type	Length	Corr. Profile	Pl./Slab Thickness	Shape
1	MAIN	-	3440	SP	59.1	152X51		ROUND
Special Features								
Special Features Comment								

Utilities (Located at)

Utility Attachments			
Telephone	West side.	Gas	
Power		Municipal	
Others		Problem (Y/N)	No
Remarks			

Approach Road / Embankment

	Last	Now	Explanation of Condition
Horizontal Alignment	9	9	Slight rise both directions.
Vertical Alignment	7	7	
Roadway Width (m)	10.000		
Embankment	8	8	
Sideslope (:1)	4.0		
(Height of Cover(m) : 4.5)			
Guardrail (Y/N)	No		
Approach Road / Embankment General Rating	7	7	

Upstream End

Culvert Component	Last	Now	Explanation of Condition
Direction	W		West
End Treatment (Concrete, Steel, Others, None)	CONCRETE		
Headwall	8	8	
Collar	7	7	7 total transverse medium width cracks
Wingwalls	X	X	
(Shape :)			
Cutoff Wall	N	N	

Upstream End				
Culvert Component		Last	Now	Explanation of Condition
Bevel End		8	8	
Heaving (mm)	0			
Invert Above/Below Stream Bed	BELOW			
Above/Below (mm)	1000			
Scour Protection		N	8	Some 1.2 m dia. rock at SB also
(Type : RIP RAP)				
(Avg. Rock Size(mm) : 800)				
Scour/Erosion		N	8	
Beavers (Y/N)	No			
Upstream End General Rating		7	7	
Bridge Culvert Barrel				
Culvert Component		Last	Now	Explanation of Condition
(Pipe # : 1, Primary Span, Location Code: MAIN, Span (mm): , Rise (mm): 3440, Type: SP)				
Barrel Last Accessible Date	13-Mar-2012			
Special Features				
Special Feature				
(Type :)				
Special Feature				
(Type :)				
Roof		8	8	
Measured Rise (mm)	3410			
Measured At Ring No.	8			
Sag (mm)	30			
Percent Sag	1			
Sidewall		8	8	
Measured Span (mm)	3460			
Measured At Ring No.	8			
Deflection (mm)	20			
Percent Deflection	1			
Floor		8	8	
Bulge (mm)	0			
Measured At Ring No.				
Abrasion (Y/N)	No			
Circumferential Seams		8	8	
Separation (mm)				
Longitudinal Seams		8	8	
Total No. of Cracked Rings	0			
Total No. of Rings with Two Cracked Seams				
Min. Remaining Steel Between Cracks (mm)				
Proper Lap (Y/N)	Yes			
Longitudinal Stagger (Y/N)	Yes			
Coating		7	7	
Corrosion By Soil (Y/N)	No			
Corrosion By Water (Y/N)	No			
Camber POS/ZERO/NEG	ZERO			
Ponding (Y/N)	No			

Bridge Culvert Barrel				
Culvert Component		Last	Now	Explanation of Condition
(Pipe # : 1, Primary Span, Location Code: MAIN, Span (mm): , Rise (mm): 3440, Type: SP)				
Fish Passage Adequacy		X	X	
Baffle		X	X	
(Type :)				
Waterway Adequacy		8	8	
Icing (Y/N)	No			
Silting (Y/N)	No			
Drift (Y/N)	No			
Barrel General Rating		8	8	
Downstream End				
Culvert Component		Last	Now	Explanation of Condition
Direction		E		East
End Treatment (Concrete, Steel, Others, None)	STEEL			
Headwall		X	X	
Collar		X	X	
Wingwalls		X	X	
(Shape :)				
Cutoff Wall		X	X	
Bevel End		8	8	
Heaving (mm)	0			
Invert Above/Below Stream Bed	BELOW			
Above/Below (mm)	200			
Scour Protection		N	8	
(Type : RIP RAP)				
(Avg. Rock Size(mm) : 500)				
Scour/Erosion		N	8	
Beavers (Y/N)	No			
Downstream End General Rating		8	8	
Structure Usage				
		Last	Now	Explanation of Condition
Channel (U/S and D/S)				
Alignment		7	7	Dugout 100 m SE.
Bank Stability		N	7	
HWM (m below Top of Culvert)				
Drift (Y/N)	No			
Channel Bottom Degrading/Aggrading				
Beavers (Y/N)	No			
(Fish Compensation Measure 1 : NONE)				
(Fish Compensation Measure 2 : NONE)				
Channel General Rating		7	7	

Maintenance Recommendations							
Inspector Recommendations	Year	Inspector Comments	Department Comments	Target Year	Est. Cost	Cat #	
SHOTCRETE REPAIRS							
PLACE ADDITIONAL RIP RAP							
REMOVE DRIFT ACCUMULATION							
INSTALL CONCRETE/STEEL LINING							
INSTALL STRUTS							
INSTALL CONCRETE COLLAR/CUTOFF							
REPAIR SEAMS							
OTHER ACTION							
OTHER ACTION							
OTHER ACTION							
OTHER ACTION							
Structural Condition Rating (Last/Now) (%)	88.9/88.9	Sufficiency Rating (Last/Now) (%)	86.5/86.5	Est. Repl. Yr	2042	Maint. Req. (Y/N)	No
Special Comments for Next Inspection			Department Comments				
Maintenance Reviewed By			Date			Estimated Total	0
Proposed Long-Term Strategy							
On 3-Year Program (Y/N)							
Proposed Action							
Previous Inspector's Name	Tim Davies		Previous Assistant's Name				
Next Inspection Date	13-Jun-2015		Previous Inspection Date	09-Feb-2009			
Inspection Cycle (Default) (months)	39						
Comment							