

Bridge Culvert Inspection				
Bridge File Number	80900 -1 Bridge Culvert		Form Type	CUL1
Year Built	1985		Lot No.	4
Bridge or Town Name	CASLAN		Inspector Name	Kris Bosters
Located Over	TRAIL-ANIMAL, OVER SP		Inspector Class	BR CLS A
Located On	855:22 C1 33.488		Assistant Name	Brian Cote
Water Body Cl./Year			Assistant Class	
Navigabil. Cl./Year			Inspection Date	11-Dec-2012
Legal Land Location	SW SEC 7 TWP 65 RGE 16 W4M		Data Entry By	Theresa Lacusta
Longitude, Latitude	-112:25:16, 54:36:15		Data Entry Date	21-Jan-2013
Road Authority	Alberta Transportation (AIT)		Reviewer Name	Eric Carcoux
Contract Main. Area	CMA07		Review Date	19-Dec-2012
Clear Roadway/Skew	12 /		Dept. Reviewer Name	Brent Herrick
AADT/Year	480 / 2011 (A)		Dept. Review Date	22-Jan-2013
Road Classification	RCU-209-110		Follow-Up By	
Detour Length (km)	50			

Bridge Culvert Information								
Number of Culverts		1						
Pipe #	Barrel	Span	Rise (or Dia.)	Type	Length	Corr. Profile	Pl./Slab Thickness	Shape
1	MAIN	-	2000	MP	25	125X26	2.8	ROUND
Special Features								
Special Features Comment								

Posting Information												
Required Vert. Clearance Posting (m)												
Posted Vertical Clearance (Y/N)			No									
Posted:	Lane	NB	On Bridge (m)		In Advance (Y/N)	No	Lane	SB	On Bridge (m)		In Advance (Y/N)	No
Remarks												

Utilities (Located at)			
Utility Attachments			
Telephone			Gas
Power			Municipal
Others			Problem (Y/N) No
Remarks			

Approach Road / Embankment				
		Last	Now	Explanation of Condition
Horizontal Alignment		7	7	Curve to North.
Vertical Alignment		6	6	Crest curve to South.
Roadway Width (m)	10.500			
Embankment		8	8	
Sideslope (___:1)	4.0			
(Height of Cover(m) : 0.5)				
Guardrail (Y/N)	No			
Approach Road / Embankment General Rating		6	6	

Upstream End				
Culvert Component		Last	Now	Explanation of Condition
Direction		W		
End Treatment (Concrete, Steel, Others, None)		NONE		
Headwall		X	X	
Collar		X	X	

Upstream End				
Culvert Component		Last	Now	Explanation of Condition
Wingwalls		X	X	
(Shape :)				
Cutoff Wall		X	X	
Bevel End		X	X	
Heaving (mm)	0			
Invert Above/Below Stream Bed	BELOW			
Above/Below (mm)	300			
Scour Protection		7	N	Snow covered
(Type : NATURAL)				
(Avg. Rock Size(mm) :)				
Scour/Erosion		7	N	
Beavers (Y/N)	No			
Upstream End General Rating		7	7	Carried fwd.
Bridge Culvert Barrel				
Culvert Component		Last	Now	Explanation of Condition
(Pipe # : 1, Primary Span, Location Code: MAIN, Span (mm): , Rise (mm): 2000, Type: MP)				
Barrel Last Accessible Date	11-Dec-2012			
Special Features				
Special Feature				
(Type :)				
Special Feature				
(Type :)				
Roof		7	7	Gravel on floor.
Measured Rise (mm)				
Measured At Ring No.				
Sag (mm)	0			
Percent Sag				
Sidewall		7	7	
Measured Span (mm)	2006			
Measured At Ring No.	2			
Deflection (mm)	6			
Percent Deflection				
Floor		7	7	Covered with gravel. 50% visible.
Bulge (mm)	0			
Measured At Ring No.				
Abrasion (Y/N)	No			
Circumferential Seams		7	7	
Separation (mm)	105			
Longitudinal Seams		X	X	
Total No. of Cracked Rings				
Total No. of Rings with Two Cracked Seams				
Min. Remaining Steel Between Cracks (mm)				
Proper Lap (Y/N)				
Longitudinal Stagger (Y/N)				
Coating		7	7	
Corrosion By Soil (Y/N)	No			
Corrosion By Water (Y/N)	No			

Bridge Culvert Barrel				
Culvert Component		Last	Now	Explanation of Condition
(Pipe # : 1, Primary Span, Location Code: MAIN, Span (mm): , Rise (mm): 2000, Type: MP)				
Camber POS/ZERO/NEG	ZERO			
Ponding (Y/N)	No			
Fish Passage Adequacy		X	X	
Baffle		X	X	
(Type :)				
Waterway Adequacy		7	7	
Icing (Y/N)	No			
Silting (Y/N)	No			
Drift (Y/N)	No			
Barrel General Rating		7	7	

Downstream End				
Culvert Component		Last	Now	Explanation of Condition
Direction		E		
End Treatment (Concrete, Steel, Others, None)	NONE			
Headwall		X	X	
Collar		X	X	
Wingwalls		X	X	
(Shape :)				
Cutoff Wall		X	X	
Bevel End		X	X	
Heaving (mm)	0			
Invert Above/Below Stream Bed	BELOW			
Above/Below (mm)	300			
Scour Protection		7	N	
(Type : NATURAL)				
(Avg. Rock Size(mm) :)				
Scour/Erosion		7	N	
Beavers (Y/N)	No			
Downstream End General Rating		7	7	carried fwd

Structure Usage				
		Last	Now	Explanation of Condition
Grade Separation				
Road Alignment		7	7	
Roadway Surface		7	7	
(Type : GRAVEL)				
Icing (Y/N)	No			
Traffic Safety Features		X	X	
Type	None			
Lighting		X	X	
Barrel Leakage (Y/N)	No			

Structure Usage				
		Last	Now	Explanation of Condition
Drainage		7	7	
Structure In Use (Y/N)	Yes			
Grade Separation General Rating		7	7	

Maintenance Recommendations							
Inspector Recommendations	Year	Inspector Comments	Department Comments	Target Year	Est. Cost	Cat #	
SHOTCRETE REPAIRS							
PLACE ADDITIONAL RIP RAP							
REMOVE DRIFT ACCUMULATION							
INSTALL CONCRETE/STEEL LINING							
INSTALL STRUTS							
INSTALL CONCRETE COLLAR/CUTOFF							
REPAIR SEAMS							
OTHER ACTION							
OTHER ACTION							
OTHER ACTION							
OTHER ACTION							
Structural Condition Rating (Last/Now) (%)	77.8/77.8	Sufficiency Rating (Last/Now) (%)	75.2/75.1	Est. Repl. Yr	2046	Maint. Req. (Y/N)	No
Special Comments for Next Inspection			Department Comments				
Maintenance Reviewed By			Date			Estimated Total	0
Proposed Long-Term Strategy							
On 3-Year Program (Y/N)							
Proposed Action							
Previous Inspector's Name	Melanie Johnson		Previous Assistant's Name				
Next Inspection Date	11-Mar-2016		Previous Inspection Date	10-Sep-2009			
Inspection Cycle (Default) (months)	39						
Comment							