

Bridge Culvert Inspection			
Bridge File Number	70755 -1 Bridge Culvert	Form Type	CUL1
Year Built	1992	Lot No.	4
Bridge or Town Name	JEFFERSON	Inspector Name	Jason Rusu
Located Over	TRIBUTARY TO ROLPH CREEK, 2.12.20.10.1, WATERCRS-ST	Inspector Class	BR CLS B
Located On	820:02 C1 8.986	Assistant Name	
Water Body Cl./Year		Assistant Class	
Navigabil. Cl./Year		Inspection Date	12-Jun-2010
Legal Land Location	NW SEC 7 TWP 2 RGE 23 W4M	Data Entry By	Erin Roberts
Longitude, Latitude	-113:04:39, 49:06:37	Data Entry Date	18-Aug-2010
Road Authority	Alberta Transportation (AIT)	Reviewer Name	Garry Roberts
Contract Main. Area	CMA25	Review Date	18-Jul-2010
Clear Roadway/Skew	12 / -20 deg. (LHF)	Dept. Reviewer Name	Lorenz Bohnert
AADT/Year	70 / 2009 (A)	Dept. Review Date	23-Aug-2010
Road Classification	RLU-209G-90	Follow-Up By	
Detour Length (km)	10		

Bridge Culvert Information

Number of Culverts	1							
Pipe #	Barrel	Span	Rise (or Dia.)	Type	Length	Corr. Profile	Pl./Slab Thickness	Shape
1	MAIN	2200	900	MPE	52	75X25	2.8	ELLIPSE
Special Features								
Special Features Comment								

Utilities (Located at)

Utility Attachments			
Telephone	West ditch	Gas	
Power	20 m east of c.l. 1 line	Municipal	
Others		Problem (Y/N)	No
Remarks			

Approach Road / Embankment

	Last	Now	Explanation of Condition
Horizontal Alignment	8	8	Bottom of sag
Vertical Alignment	7	7	
Roadway Width (m)	12.000		
Embankment	7	5	1.5m (d) x 2.0m (w) x 5m (l) Erosion from ditch drainage to NE
Sideslope (__:1)	3.0		
(Height of Cover(m) : 5.5)			
Guardrail (Y/N)	No		
Approach Road / Embankment General Rating	7	7	

Upstream End

Culvert Component	Last	Now	Explanation of Condition
Direction	E		U/S east
End Treatment (Concrete, Steel, Others, None)	STEEL		
Headwall	X	X	
Collar	X	X	
Wingwalls	X	X	
(Shape :)			
Cutoff Wall	X	X	

Upstream End				
Culvert Component		Last	Now	Explanation of Condition
Bevel End		8	8	
Heaving (mm)	0			
Invert Above/Below Stream Bed	BELOW			
Above/Below (mm)	100			
Scour Protection		N	7	
(Type :)				
(Avg. Rock Size(mm) :)				
Scour/Erosion		N	7	
Beavers (Y/N)	No			
Upstream End General Rating		8	7	
Bridge Culvert Barrel				
Culvert Component		Last	Now	Explanation of Condition
(Pipe # : 1, Primary Span, Location Code: MAIN, Span (mm): 2200, Rise (mm): 900, Type: MPE)				
Barrel Last Accessible Date	12-Jun-2010			
Special Features				
Special Feature				
(Type :)				
Special Feature				
(Type :)				
Roof		8	8	At midlength of pipe
Measured Rise (mm)	2218			
Measured At Ring No.				
Sag (mm)				
Percent Sag	0			
Sidewall		8	8	inward At midlength of pipe
Measured Span (mm)	2185			
Measured At Ring No.				
Deflection (mm)				
Percent Deflection				
Floor		N	7	
Bulge (mm)	0			
Measured At Ring No.				
Abrasion (Y/N)	No			
Circumferential Seams		8	8	
Separation (mm)	0			
Longitudinal Seams		X	X	
Total No. of Cracked Rings	0			
Total No. of Rings with Two Cracked Seams	0			
Min. Remaining Steel Between Cracks (mm)	0			
Proper Lap (Y/N)				
Longitudinal Stagger (Y/N)				
Coating		6	6	
Corrosion By Soil (Y/N)	No			
Corrosion By Water (Y/N)	Yes			
Camber POS/ZERO/NEG	ZERO			
Ponding (Y/N)	No			

Bridge Culvert Barrel				
Culvert Component		Last	Now	Explanation of Condition
(Pipe # : 1, Primary Span, Location Code: MAIN, Span (mm): 2200, Rise (mm): 900, Type: MPE)				
Fish Passage Adequacy		X	8	
Baffle		X	X	
(Type :)				
Waterway Adequacy		9	9	
Icing (Y/N)	No			
Silting (Y/N)	No			
Drift (Y/N)	No			
Barrel General Rating		8	8	
Downstream End				
Culvert Component		Last	Now	Explanation of Condition
Direction		W		D/S WEST
End Treatment (Concrete, Steel, Others, None)	STEEL			
Headwall		X	X	
Collar		X	X	
Wingwalls		X	X	
(Shape :)				
Cutoff Wall		X	X	
Bevel End		8	7	
Heaving (mm)	0			
Invert Above/Below Stream Bed	BELOW			
Above/Below (mm)	100			
Scour Protection		8	7	
(Type : RIP RAP)				
(Avg. Rock Size(mm) : 400)				
Scour/Erosion		8	7	
Beavers (Y/N)	No			
Downstream End General Rating		8	7	
Structure Usage				
		Last	Now	Explanation of Condition
Channel (U/S and D/S)				
Alignment		9	9	
Bank Stability		8	6	Minor erosion to South D/S
HWM (m below Top of Culvert)				No visible HWM
Drift (Y/N)	No			
Channel Bottom Degrading/Aggrading	DEGRADING			
Beavers (Y/N)	No			
(Fish Compensation Measure 1 : NONE)				
(Fish Compensation Measure 2 : NONE)				
Channel General Rating		9	6	

Maintenance Recommendations							
Inspector Recommendations	Year	Inspector Comments	Department Comments	Target Year	Est. Cost	Cat #	
SHOTCRETE REPAIRS							
PLACE ADDITIONAL RIP RAP							
REMOVE DRIFT ACCUMULATION							
INSTALL CONCRETE/STEEL LINING							
INSTALL STRUTS							
INSTALL CONCRETE COLLAR/CUTOFF							
REPAIR SEAMS							
OTHER ACTION							
OTHER ACTION							
OTHER ACTION							
OTHER ACTION							
Structural Condition Rating (Last/Now) (%)	88.9/88.9	Sufficiency Rating (Last/Now) (%)	92.5/88.7	Est. Repl. Yr	2043	Maint. Req. (Y/N)	No
Special Comments for Next Inspection			Department Comments				
Maintenance Reviewed By			Date		Estimated Total	0	
Proposed Long-Term Strategy							
On 3-Year Program (Y/N)							
Proposed Action							
Previous Inspector's Name	Tim Davies		Previous Assistant's Name				
Next Inspection Date	12-Sep-2013		Previous Inspection Date	01-Mar-2007			
Inspection Cycle (Default) (months)	39						
Comment							